

# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**DEHN + SÖHNE GmbH + Co.KG**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: SURGE PROTECTION DEVICE (DEHN)*

*DEHNBLOC SERIES – DB1255H; DB3255H; DBM1255; DBM1255L;*

*$U_c = 255V$ ,  $I_{imp} = 50kA$  (10/350 $\mu$ s),  $U_p \leq 2.5kV$ , 50/60Hz*

**Test Laboratory:**

KEMA Netherlands

**Test Report No(s):** 2095811.50 / 51

**RCC No:** 1304666

  
NRCS Electro-Tech General Manager

**In accordance to(Standards):**

IEC 61643-1: 1998 +A1

**Period of Validity**

22/04/2013 to 22/04/2016

**DATE**

30/04/2013



# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**DEHN + SÖHNE GmbH + Co.KG**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: SURGE PROTECTION DEVICE (DEHN)*

*DEHNGUARD M SERIES; DGMTN 275(FM); TT2P275(FM); TN275NL(FM); TT2P275NL(FM); 2W275(FM);  
2W150(FM); TNC275(FM); 3W275150(FM); 3W275(FM); TNS275(FM); TT275(FM); 4W275(FM);  
TNS275NL(FM); TT275NL(FM)*


$U_c = 150V, 255V, 275V, I_{max} = 40kA, U_p \leq 0.7kV, 1.25kV, 1.5kV, 50/60Hz$

**Test Laboratory:**

KEMA Netherlands

**Test Report No(s):** 2095604.67/ 68/ 69/ 69/ 70/ 71

**RCC No:** 1304667

  
NRCS Electro-Tech General Manager

**In accordance to(Standards):**

IEC 61643-1: 1998 +A1

**Period of Validity**

22/04/2013 to 22/04/2016

**DATE**

30/04/2013



# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**DEHN + SÖHNE GmbH + Co.KG**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: SURGE PROTECTION DEVICE (DEHN)*

*DEHNRAIL M SERIES – DRM2P255(FM); DRM2P30(FM); DRM2P60(FM); DRM2P75(FM); DRM2P150(FM);  
U<sub>c</sub> = 30V, 60V, 75V, 150V, 255V, U<sub>p</sub> ≤ 180V, 350V, 400V, 640V, 1250V (L-N), 630V, 730V, 800V, 1500V (L/N-PE),  
50/60Hz*

**Test Laboratory:**

KEMA Netherlands

**Test Report No(s):** 2095810.50/ 51/ 52/ 53/ 54

**RCC No:** 1304668

  
\_\_\_\_\_  
**NRCS Electro-Tech General Manager**

**In accordance to(Standards):**

IEC 61643-1: 1998 +A1

**Period of Validity**

22/04/2013 to 22/04/2016

**DATE**

30/04/2013



# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**DEHN + SÖHNE GmbH + Co.KG**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: SURGE PROTECTION DEVICE (DEHN)*

*DEHNGUARD S SERIES; DGS275(FM); DGS75(FM); DGS150(FM); DGS320(FM); DGS385(FM); DGS440(FM); DGS600(FM);  $U_c = 75V, 150V, 275V, 320V, 385V, 440V, 600V$ ;  $I_{max} = 30kA, 40kA$ ,  $U_p \leq 0.4kV, 0.7kV, 1.25kV, 1.5kV, 1.75kV, 2kV, 2.5kV, 50/60Hz$*

**Test Laboratory:**

KEMA Netherlands

**Test Report No(s):** 2095604.51/ 52/ 53/ 54/ 55/ 56/ 57

**RCC No:** 1304669

  
NRCS Electrotechnical General Manager

**In accordance to(Standards):**

IEC 61643-1: 1998 +A1

**Period of Validity**

22/04/2013 to 22/04/2016

**DATE**

30/04/2013



# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**DEHN + SÖHNE GmbH + Co.KG**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: SURGE PROTECTION DEVICE (DEHN)*

*DEHNVENTIL M SERIES; DVMTN255(FM); DVMTT2P255(FM); DVMTNC255(FM); DVMTNS255(FM); DVMTT255(FM);  $U_c = 255V$ ,  $I_{max} = 25kA$  (L-N/PEN);  $U_p \leq 1.5kV$  (L-N, N-PE); 25kA, 50kA, 100kA (N-PE), 50/60Hz*

**Test Laboratory:**

KEMA Netherlands

**Test Report No(s):** 2095605.50/ 51/ 52/ 53/ 54

**RCC No:** 1304670A

  
**NRCS Electro-Tech General Manager**

**In accordance to(Standards):**

IEC 61643-1: 1998 +A1

**Period of Validity**

22/04/2013 to 22/04/2016

**DATE**

28/06/2013



# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**DEHN + SÖHNE GmbH + Co.KG**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: SURGE PROTECTION DEVICE (DEHN)*

*900 350(DVA CSP 3P 100); 900 011(DVA CSP MOD255(L-N)); 900 300(DVA CSP MOD NPE 100);*

*L-N:  $U_c = 255V$ ,  $I_{imp} = 25kA$ ,  $I_n = 25kA$ ,  $U_p \leq 1.5kV$ , 50/60Hz*


*L-PE:  $U_c = 255V$ ,  $I_{imp} = 100kA$ ,  $I_n = 100kA$ ,  $U_p \leq 1.5kV$ , 50/60Hz*

**Test Laboratory:**

KEMA Quality B.V

**Test Report No(s):** 2134376.50

**RCC No:** 1309739



**NRCS Electro-Tech General Manager**

**In accordance to(Standards):**

IEC 61643-1:2005

**Period of Validity**

12/09/2013 to 12/09/2016

**DATE** 12/09/13

